

**TOWNSHIP OF LEBANON
BOARD OF HEALTH REORGANIZATION MEETING
AGENDA
March 6, 2024
6:30 p.m.**

CALL TO ORDER

- Statement of Compliance
- Flag Salute
- Moment of Silence
- Roll Call

NOMINATION OF 2024 BOARD CHAIR

PRESENTATION OF MINUTES

- 12/6/2023 Regular Session Meeting Minutes

PUBLIC COMMENT *(limited to three minutes per speaker)*

- Limited to Agenda Items Only

RESOLUTIONS

NO. 01-2024 RESOLUTION SETTING THE ANNUAL MEETING SCHEDULE FOR
TOWNSHIP BOARD OF HEALTH MEETINGS FOR CALENDAR YEAR 2024

UNFINISHED BUSINESS

- None

NEW BUSINESS

- Septic System Alteration Waiver
227 Musconetcong River Road
Block 60, Lot 19

The following waivers will need to be acted on by the Board:

1. The proposed disposal field is not the minimum 25 feet to the existing dwelling. The proposed disposal field is shown 23 feet from the existing dwelling.
2. The toe of the slope is not the counties policy of a minimum 10 feet from the property line. The toe of the slope is shown 6 feet from the property.

The Board will need to act or acknowledge the following as a condition of making the application to the DEP.

1. A sewage ejector pump is being proposed for a single basement bathroom, the pump discharges to the gravity piping within the interior of the dwelling and the pumping volume per cycle is small, a waiver for the disposal area size not being oversized by 50 percent is being requested, a TWA permit will need to be obtained from the DEP.

PUBLIC COMMENT *(limited to three minutes per speaker)*

ADJOURNMENT