

**TOWNSHIP OF LEBANON  
BOARD OF HEALTH  
AGENDA  
April 3, 2024  
6:00 p.m.**

**CALL TO ORDER**

- Statement of Compliance
- Flag Salute
- Moment of Silence
- Roll Call

**PRESENTATION OF MINUTES**

- 3/6/2024 Regular Session Meeting Minutes

**PUBLIC COMMENTS**

- Limited to Agenda Items Only

**NEW BUSINESS**

- Septic System Alteration Waiver Request  
Municipality: Lebanon Township  
Block 69, Lot 23.01  
Location: 116 Musconetcong River Road

The following waivers will need to be acted on by the Board:

1. The existing well located on Lot 22 is not the minimum 100 feet to the proposed disposal field. The existing well is shown 86.4 feet from the proposed disposal field. The distance may be decreased by the administrative authority to a minimum of 50 feet only when the well is provided a water-tight casing to a depth of 50 feet or more. An existing well record on file with Hunterdon County Department of Health for Lot 22 indicates this well has more than 50 feet of casing.
2. The proposed disposal bed for this design shall have a minimum of 669.2 square foot area. Due to site constraints the proposed disposal bed will have less than this square foot area. The proposed disposal bed is shown with 432 square feet.
3. The proposed disposal bed will have more than the required 18 inches of fill above the field. The proposed disposal bed is shown with 37 inches of fill above the field.
4. The proposed disposal bed is less than 50 feet to the drainage pipe and inlet. The Engineer has proposed to install a PVC liner on the north and east side of the excavation closest to

the drainage inlets.

- Septic System Alteration Waiver Request  
Municipality: Lebanon Township  
Block 40, Lot 32  
Location: 9 Spring Mountain Road

The following waiver requests that will need to be acted by the Board:

1. The existing well is not the minimum 100 feet to the proposed disposal field. The existing well is shown 64 feet from the proposed disposal field. The distance may be decreased by the administrative authority to a minimum of 50 feet only when the well is provided a water-tight casing to a depth of 50 feet or more. Hunterdon County Department of Health has no information on this existing well. The Department would recommend a report from a well driller to determine how much casing is in the well. The Engineer is also proposing an ultraviolet device be installed on the well to address this issue. Hunterdon County Department of Health would require a passing coliform test from a NJ certified laboratory after the ultraviolet light has been installed.

### **UNFINISHED BUSINESS**

- **WAIVER APPROVED 12/6/2023**  
Installation of Septic System in Township R.O.W.  
Block 27, Lot 5  
Location: 3 High View Street

### **PUBLIC COMMENT**

### **EXECUTIVE SESSION**

### **ADJOURNMENT**