

**TOWNSHIP OF LEBANON
BOARD OF HEALTH
AGENDA
May 1, 2024
6:30 p.m.**

CALL TO ORDER

- Statement of Compliance
- Flag Salute
- Moment of Silence
- Roll Call

PRESENTATION OF MINUTES

- 7/5/2023 Regular Session Meeting Minutes
- 4/3/2024 Regular Session Meeting Minutes

PUBLIC COMMENT *(limited to three minutes per speaker)*

- Limited to Agenda Items Only

NEW BUSINESS

- Septic System Alteration Waiver Request
Municipality: Lebanon Township
Block 35, Lot 59
Location: 521 West Hill Road

The following waivers will need to be acted on by the Board:

1. The proposed disposal bed will be only 89 feet from the existing well, which does not meet the minimum distance setback of 100 feet. As per 7:9A-4.3, the distance can be reduced to 50 feet provided there is 50 feet of casing. Since there is no well record available, recommend to the Board that a ultraviolet treatment device be installed on the well and a passing water sample for coliform be collected after treatment for added protection.
2. The code requires a minimum of two soil logs be conducted when designing a septic system. The proposed design shows that only one soil log was done. Engineer shall explain the site conditions and the reason why only one soil log was performed to the satisfaction of the Board.

PUBLIC COMMENT *(limited to three minutes per speaker)*

ADJOURNMENT