

**TOWNSHIP OF LEBANON
BOARD OF HEALTH
AGENDA
December 4, 2024
6:30 p.m.**

CALL TO ORDER

- Statement of Compliance
- Flag Salute
- Moment of Silence
- Roll Call

PRESENTATION OF MINUTES

- 10/2/2024 Regular Session Meeting Minutes

PUBLIC COMMENT *(limited to three minutes per speaker)*

- Limited to Agenda Items Only

UNFINISHED BUSINESS

- Septic System Alteration Waiver – Proposed Expansion
Municipality: Lebanon Township
Block: 24 Lot: 50
Location: 9 Orchard Street

Hunterdon County Health Department has received septic alteration plans dated November 5, 2024, designed by Erica Busch, PE for a proposed expansion from 3 to 4-bedroom dwelling. The design is in full conformance with 7:9A except for the following which will need to be acted on by the Board.

1. Lebanon Township Ordinance 6.1c, Soil Permeability Class Rating tests shall not be used in soils which are sandy clay loam, unless the results of the tests are confirmed by permeability tests conducted in-situ as permitted by code. The Engineer shall explain the soil testing results on the property to the Board and why an in-situ test was not performed to the satisfaction of the Board.

PUBLIC COMMENT *(limited to three minutes per speaker)*

ADJOURNMENT