

TOWNSHIP OF LEBANON
BOARD OF HEALTH
AGENDA
February 5, 2025
6:30 p.m.

CALL TO ORDER

- Statement of Compliance
- Flag Salute
- Moment of Silence
- Roll Call

NOMINATION OF 2025 BOARD CHAIR

PRESENTATION OF MINUTES

- 12/4/2024 Regular Session Meeting Minutes

PUBLIC COMMENT *(limited to three minutes per speaker)*

- Limited to Agenda Items Only

RESOLUTIONS

NO. 01-2025 RESOLUTION SETTING THE ANNUAL MEETING SCHEDULE FOR
TOWNSHIP BOARD OF HEALTH MEETINGS FOR CALENDAR YEAR 2025

NEW BUSINESS

- Tax Assessor Bedroom Count Confirmations
- Septic System Alteration Waiver
Block: 10 Lot: 41.01
Location: 178 Buffalo Hollow Road

Hunterdon County Department of Health has received revised septic alteration plans dated December 30, 2024, by Erica Busch, PE, which now show the correct location of the existing well on this property. The original design showed the well at the rear of the property, the plans now show the accurate location of the well, which was determined after the new disposal bed was installed.

The Board will need to act on the following waiver request.

1. The installed disposal bed is only 83 feet from the existing well, which does not meet the minimum distance of 100 feet. As per 7:9A-4.3, the distance can be reduced to 50 feet

provided there is 50 feet of casing in the well. The well report provided by D&L Pump shows that the casing is only 16.7 feet. Therefore, the Engineer is proposing to install an ultraviolet light on the well for and have a water test done for coliform after treatment for added protection.

Since this is a malfunctioning system, as per 7:9A 3.3 (e)2ii, and is closer to conformance with the requirements of this chapter, the Board can consider the approval of the proposed design.

PUBLIC COMMENT *(limited to three minutes per speaker)*

ADJOURNMENT